



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Clearview Regional School District Field House

420 Cedar Road
Mullica Hill, NJ 08062

Results of Lead Analysis

Date & Time Sampled: 04/14/2017 09:42 - 09:54

Date & Time Analyzed: 04/26/2017 21:32 - 22:17

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
FH-S-1	<2.00	15.5
FH-HB-1	<2.00	15.5
FH-S-2	<2.00	15.5
FH-S-3	5.27	15.5
FH-S-4	2.86	15.5
FH-WF-1	<2.00	15.5
FH-WF-2	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

5/5/17

Date